FUSCO ENGINEERING L'AND SURVEYING, P.C.

Consulting Engineers

Alfred A. Fusco, Jr., P.E., Principal

Alfred A. Fusco, III, General Manager

233 East Main Street
Middletown, NY 10940
Phone: (845) 344-5863
Fax: (845) 956-5865

19 Waywayup Lane
Port Jervis, NY 12771
Phone: (845) 956-5866

September 18, 2018

Donald Serotta, Planning Board Chairman Town of Chester 1786 Kings Highway Chester, NY, 10918

Re:

191 LeHigh Avenue Our File No. CH-143

Dear Chairman Serotta,

We have reviewed the latest submission and offer the following:

PROJECT:

Name:

Commercial Lot

SBL:

3-1-14.1

Acres:

1.0 Acre

Zone:

I Zone

Material:

9/6/18 Revised Fellenzer plans

Comments:

- 1. Board had requested consideration of concrete (masonry) dumpster enclosure.
- 2. Add notes regarding compliance with Building Department for caretaker in the existing building as a condition of approval that the applicant submit a Building Permit with plans stamped by a Professional NYS Engineer or Architect that the building is in compliance with the Building Code for both commercial and residential use. Fence also requires a permit. Also, the Planning Board as per Building Department may wish to limit bedrooms or square footage.
- 3. Consider ADA parking closer to the office area.
- 4. Detail of sign requested.
- 5. Lighting requested to have motion detectors; please note.
- 6. Surveyor noted on plan needs stamp and signature on final plan.
- 7. Engineer to stamp and sign final plan.
- 8. Board to consider if hours of operation are acceptable.
- 9. Sign off required by landscape architect consultant of Town.
- 10. Board comments.

Action:

SEORA

Pleasure of Board.

Please advise if you have any questions.

Very truly yours,

Affred A. Fusco, Jr., P.E. Fusco Engineering

& Land Surveying, P.C.

AAF/cam

Cc:

Alexa Burchianti