

July 18, 2022

Town of Chester Planning Board
Attn: Melissa Foote, Planning & Zoning Secretary
1786 Kings Highway
Chester, NY 10918

Ref: Superio-193 Black Meadow Road-Septic System
Town of Chester: 6-1-100

Dear Planning Board Members,


The site is currently being serviced by the existing subsurface septic system. the system design as per the approved plan for its construction was for forty (40) employees at a flow of twenty-five (25) gallons per day per employee. Currently the facility has fifteen (15) employees and anticipates twenty to twenty-five (20-25) employees once the addition is completed. This is still under the design loading and in addition any new facilities will utilize water saving devices.

There is no evidence of failure in the area of the existing system.

If you require anything additional please contact our office.

Thank you.

Sincerely,



Lawrence Torro, PE
Project Engineer