FUSCO ENGINEERING LAND SURVEYING, P.C. Consulting Engineers

Alfred A. Fusco, Jr., P.E., Principal

Alfred A. Fusco, III, General Manager

233 East Main Street Middletown, NY 10940 Phone: (845) 344-5863 Fax: (845) 956-5865

19 Waywayup Lane Port Jervis, NY 12771 Phone: (845) 956-5866

April 14, 2015

Donald Serotta, Chairman Town of Chester Planning Board 1786 Kings Highway Chester, NY, 10918

Re: Primo Sports Complex

Orange County, New York

Dear Chairman Serotta.

We have reviewed the project submittals and offer the following:

Project: Primo Sports Complex

Zone: SR-1 (Suburban Residential)

Annual Membership Club providing outdoor recreation Classification:

Acreage: 25.8 Acres

Variance: **ZBA** 50 acres to 25.8

Material Reviewed: Preliminary Site Plan (Pages 1/16) Fellenzer Engineering LLP Revised 4/1/15

> SWPPP with date dated 4/1/15 Engineer's Report dated 4/1/15

Cover letter from Fellenzer Engineering dated 4/1/15 Orange County Planning Dept. 239GML Review

NYSDOT lead agency letter

Comments:

- 1. Include copy of variance on plan.
- Stamped plans by surveyor and engineer.
- Identify curbing off Tetz and in parking area; show radii and label sidewalks and show detail.
- Show knox box for emergency access.
- 5. Identify variable ROW.
- 6. Landscape plan approval by Town Landscape/Architecture Professional.

- 7. Show end section for guide rail.
- 8. NYSDOT requests Traffic Impact Study (see enclosed correspondence).
- 9. Orange County Planning Dept. had comments regarding lighting; applicant to address concerns (i.e. plantings, on Route 94 Engineer to look at shielding). We need light pole foundations shown.
- 10. Need SPEDES permits for stormwater and sanitary waste.
- 11. Need Orange County Dept. of Health water supply approval.
- 12. Commitment to be on plan for \$10,000 cash bond to be held in escrow until NYSDOT ROW work is done for turning lane into Tetz Road.
- 13. Escrow accounts to be set up for required inspections.
- 14. SWPPP monthly reports to Town Engineer for MS4 reporting.
- 15. Pave cul-de-sac for emergency entrance.
- 16. Board comments.

Action:

- 1. Public Hearing remain open or close
- 2. SEQRA review

Please advise if you have any questions.

Very truly yours,

Alfred A. Fusco, Jr., P.E. Fusco Engineering & Land Surveying, P.C. AAF/sdb