## FUSCO ENGINEERING & LAND SURVEYING, P.C.

Consulting Engineers

Alfred A. Fusco, Jr., P.E., Principal

Alfred A. Fusco, III, General Manager

- 233 East Main Street
  Middletown, NY 10940
  Phone: (845) 344-5863
  Fax: (845) 956-5865
- 19 Waywayup Lane
  Port Jervis, NY 12771
  Phone: (845) 956-5866

November 30, 2021

Donald Serotta, Chairman Town of Chester Planning Board 1786 Kings Highway Chester, NY, 10918

Re:

Greycourt Road Solar

190 Greycourt Road

Town of Chester, Orange County, New York

Our File #CH-211

Dear Chairman Serotta,

We have reviewed the application package, long form EAF and plans for the above mentioned plan and offer the following:

Project:

Site Plan for Greycourt Road Solar

Zone:

OP Zone

Acreage:

22.9 Ac (691,229 SF)

SBL:

3-1-72

Material:

New application, Long Form EAF, Site Plan

## Comments:

- 1. A landscaping plan is required. Buffer landscaping will be necessary for exposed areas to commercial traffic.
- 2. The plans do not clearly label the existing wetlands. It appears that there is construction proposed within wetland areas.
- 3. A Stormwater Pollution Prevention Plan is currently under review. The plans should clearly note the total area of disturbance. Also, there needs to be a SWPPP plan included with the site plan which incorporates all the items discussed in the SWPPP report.
- 4. It appears based upon the LoD (limits of disturbance shown) that a full SWPPP is required.

- 5. A visual analysis should be provided to address visual impacts to all adjoining areas as well as areas determined to be of significant visual impact by the planning board.
- 6. Provide letter of no impact from SHPO.
- 7. Provide a profile for the driveway with drainage proposed drainage improvements as necessary.
- 8. Provide suitable erosion and sediment control details on the plans.
- 9. Provide a driveway cross section detail.
- 10. Provide slope stabilization details on plans for steep slope disturbance.
- 11. The EAF indicates approvals required from NYSDAM and NYSDEC. The EAF should elaborate. Also, site plan approval and special use permit is required from the Town of Chester.
- 12. The decommissioning plan should be reviewed by the Planning Board. Also, a decommissioning bond is recommended to assure compliance.
- 13. Provide sufficient detail to the Planning Board regarding the site contamination listed in the long form EAF.

## Action:

- 1. 239GML
- 2. Public hearing.

Please advise if you have any questions.

Very truly yours,

Alfred A. Fusco, Jr., P.E.

Fusco Engineering

& Land Surveying, P.C.

AAF/cam